Seisodin Tilia T100P



Statement of Compliance with DPWH Requirements

17th January 2024

To whom it may concern.

We. Seisodin ApS, whose offices are located in Ebberup, Denmark, hereby confirm and certify to have reviewed the 2015 DPWH Guidelines and Implementing Rules on Earthquake Instrumentation for buildings and verified that the Seisodin Tilia seismic accelerograph (ERI) complies and exceeds the minimum technical requirements.

Compliance Check Sheet for Seisodin Tilia TOOP

	otor	

Seismic qualified

Tested by

recognized international testing

Stores seism ic activity

Equipped with fault detection Real-time Alarm Info Internal Battery Backup

Design life MTBE

Sensitive axis

Natural Damping Frequency Damping Sensitivity **Bandwidth**

Environment Recording

Sampling Frequency

Tim e

RMS Noise

Media Continous Recording

AD Converter

Timing

Interval

Accuracy Type

(continued on page 2)

Requirement by DPW H

laboratory

Yes

Yes Audio, Visual or both

Yes

10 years

40.000 hours Minimum 3 components (vertical, longitudinal and

transverse)

Above 50hz

60-70 percent critical

DC to 100Hz IP 67

Minimum 100 samples per second

From at least 20 seconds before the ground shaking begins until 30 seconds after

the last triggering level

motion <40 ug over 0-30Hz Memory Card

Capable of continous recording

16 bits

Half a second or less

Plus or minus 0.2 second per 100 seconds GPS or NTP sever

(continued on page 2)

Tilia T100P

Yes - Seismically Qualified for Seismic Zone 4 according to 60068-3-3 by accredited test laboratory.

Test report available.

Yes

Yes - LED's and Control Panel Yes - Audio and Visual Yes - Up to 12 hours or more

10 years

100,000 hours

3 orthogonal axis (X,Y,Z)

Above 200Hz

70 percent 2g or 4g available DC to 200Hz

IP 67

50, 100, 200, 250, 500, 1000 samples per second (user

selectable)

Yes - user selectable from 120 seconds before to 180

seconds after.

<40 ug over 0-30Hz Memory Card (micro-SD) Continous recording in a ring-buffer structure.

24 bits

Yes. +/-10usec after GPS fix. 40nsec synchronization

between daisy chained

devices.

Yes

GPS, PTP or NTP

(continued on page 2)

Seisodin Tilia T100P



Statement of Compliance with DPWH Requirements

(continued) Compliance Check Sheet for Seisodin Tilia TOOP

Parameter	Requirement by DPWH	Tilia T100P

Triggering Method

Power

Battery

Ethernet

Protocol

Level Tim e

Communication

Additional features

Pendulum or other device using earthquake motion as an exciting force 0.5 to 100 gals Full operation of accelerograph/velocity in not over 0.1 second after

activation.

Battery maintained by charger

10 base –T or 100 base-TX TCP/IP FTP/SFTP MEMS Accelerom eters

0.0001g to 4g Yes, continuous recording

Internal battery maintained by charger

10 base –T or 100 base-TX TCP/IP, FTP

Connection between instruments across multiple floors is easily achieved by using the standard daisy chaining feature.

To comply with the requirements the system must consist of the following parts: Tilia T100P, I x Battery, I x Tilia Relay Option, I x Tilia Control Panel Systems for The Philippines are quoted with all of the above items included.



Seisodin ApS Lindhovedvej 33C 5631 Ebberup Denmark VATID: DK41747641

